

Хабаровские ЭС КДЗ 21.06.2023

Наименование подстанции	Дисп. наим.	Сном, МВА	4:00				11:00				17:00				22:00				Максимальное значение				
			P	Q	S	загр.	P	Q	S	загр.	P	Q	S	загр.	P	Q	S	загр.	P	Q	S	загрузка,	
			МВт	МВар	МВА	%	МВт	МВар	МВА	%	МВт	МВар	МВА	%	МВт	МВар	МВА	%	МВт	МВар	МВА	%	
ПС 110 кВ АК	1Т	25	9.328	2.49	9.655	38.62	9.642	2.621	9.992	39.97	11.54	3.127	11.95	47.81	10.35	2.697	10.69	42.78	11.54	3.127	11.95	47.81	19
ПС 110 кВ АК	2Т	25	9.328	2.49	9.655	38.62	9.642	2.621	9.992	39.97	11.54	3.127	11.95	47.81	10.35	2.697	10.69	42.78	11.54	3.127	11.95	47.81	19
ПС 35 кВ Анастасьевка	1Т	6.3																					
ПС 35 кВ Анастасьевка	2Т	6.3																					
ПС 35 кВ Балтика	1Т	4	1.576	0.716	1.731	43.28	1.4	0.636	1.538	38.45	1.296	0.589	1.424	35.59	1.672	0.76	1.837	45.92	1.672	0.76	1.837	45.9156	19
ПС 35 кВ Балтика	2Т	4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ Березовка	1Т	10	1.8	0.72	1.939	19.39	2.16	1.08	2.415	24.15	2.16	0.72	2.277	22.77	2.16	0.36	2.19	21.9	2.16	1.08	2.415	24.1495	19
ПС 110 кВ Березовка	2Т	10	3.42	0.36	3.439	34.39	3.96	0.54	3.997	39.97	2.88	0.72	2.969	29.69	3.42	0.54	3.462	34.62	3.96	0.72	3.997	39.9665	19
ПС 110 кВ Бикин	1Т	16	4.6	0.8	4.669	29.18	5	1	5.099	31.87	4	1.6	4.308	26.93	5.2	1	5.295	33.1	5.2	1.6	5.295	33.0955	19
ПС 110 кВ Бикин	2Т	10	4.4	1	4.512	45.12	5	1.2	5.142	51.42	8.8	1.8	8.982	89.82	5.8	1.2	5.923	59.23	8.8	1.8	8.982	89.822	19
ПС 35 кВ Благодатное	1Т	4	0.528	0.117	0.541	13.52	0.524	0.12	0.538	13.45	0.569	0.118	0.581	14.52	0.5	0.11	0.512	12.81	0.569	0.12	0.581	14.5238	19
ПС 35 кВ Благодатное	2Т	4	0.386	0.065	0.391	9.783	0.377	0.064	0.382	9.556	0.357	0.063	0.363	9.063	0.364	0.061	0.369	9.218	0.386	0.065	0.391	9.7826	19
ПС 35 кВ БН	1Т	16	1.44	0	1.44	9	0.72	0.48	0.865	5.408	6.96	0.96	7.026	43.97	6	0.72	6.043	37.77	6.96	0.96	7.026	43.9118	19
ПС 35 кВ БН	2Т	16	6.48	0.24	6.484	40.53	6.72	0.48	6.737	42.11	5.76	0.48	5.78	36.12	7.92	0.72	7.953	49.7	7.92	0.72	7.953	49.7041	19
ПС 110 кВ Бройлерная 2	1Т	6.3	4.725	0.945	4.819	76.49	3.675	0.84	3.77	59.84	5.46	0.945	5.541	87.96	3.36	0.945	3.49	55.4	5.46	0.945	5.541	87.9552	19
ПС 110 кВ Бройлерная 2	2Т	6.3	3.2	0.2	3.206	50.89	2.8	0.2	2.807	44.56	3	0.2	3.007	47.72	2.2	0.4	2.236	35.49	3.2	0.4	3.206	50.8928	19
ПС 35 кВ Бычиха	1Т	4	2.7	0.42	2.732	68.31	2.34	0.36	2.368	59.19	3.06	0.36	3.081	77.03	2.34	0.36	2.368	59.19	3.06	0.42	3.081	77.0276	19
ПС 35 кВ Бычиха	2Т	4	3.18	0.54	3.226	80.64	3	0.48	3.038	75.95	1.8	0.3	1.825	45.62	2.88	0.48	2.92	72.99	3.18	0.54	3.226	80.6381	19
ПС 110 кВ ВДЗ (БНС ТЭЦ-3)	1Т	10	0.72	0	0.72	7.2	1.44	0	1.44	14.4	0.72	0.72	1.018	10.18	0.72	0	0.72	7.2	1.44	0.72	1.44	14.4	19
ПС 110 кВ ВДЗ (БНС ТЭЦ-3)	2Т	6.3	0.1	0	0.1	1.587	0.1	0	0.1	1.587	0.1	0	0.1	1.587	0.1	0	0.1	1.587	0.1	0	0.1	1.5873	19
ПС 35 кВ Виноградовка	1Т	6.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 35 кВ Водозабор	1Т	4	0	0	0	0	0.08	0.08	0.113	2.828	0.08	0.08	0.113	2.828	0.16	0.08	0.179	4.472	0.16	0.08	0.179	4.47214	19
ПС 35 кВ Водозабор	2Т	4	0	0	0	0	0.16	0.08	0.179	4.472	0.08	0.08	0.113	2.828	0.16	0.08	0.179	4.472	0.16	0.08	0.179	4.47214	19
ПС 110 кВ Восточная	1Т	25	15.24	3.273	15.59	62.34	15.09	1.491	15.17	60.66	20.89	3.053	21.11	84.45	20.93	2.709	21.11	84.44	20.93	3.273	21.11	84.446	19
ПС 110 кВ Восточная	2Т	25	1.072	0.192	1.089	4.355	1.028	0.185	1.045	4.179	1.67	0.252	1.689	6.757	1.454	0.218	1.471	5.883	1.67	0.252	1.689	6.75721	19
ПС 35 кВ Втрюмет	1Т	6.3	0.716	0.256	0.761	12.07	0.772	0.284	0.822	13.05	1.069	0.365	1.13	17.93	0.968	0.29	1.011	16.05	1.069	0.365	1.13	17.9321	19
ПС 35 кВ Втрюмет	2Т	6.3	2.214	0.702	2.323	36.87	2.138	0.712	2.254	35.77	3.01	1.244	3.257	51.69	2.635	1.15	2.875	45.64	3.01	1.244	3.257	51.694	19
ПС 110 кВ Вяземская	1Т	10	3.6	0.84	3.697	36.97	3.6	0.72	3.671	36.71	3.84	0.96	3.958	39.58	3.36	0.84	3.463	34.63	3.84	0.96	3.958	39.5818	19
ПС 110 кВ Вяземская	2Т	10	2.76	0.6	2.824	28.24	3.6	0.36	3.618	36.18	3.12	0.72	3.202	32.02	3	0.72	3.085	30.85	3.6	0.72	3.618	36.1796	19
ПС 110 кВ ГВФ	1Т	25	15.5	3.7	15.94	63.74	15.5	3.6	15.91	63.65	16.7	4.1	17.2	68.78	16.1	3.9	16.57	66.26	16.7	4.1	17.2	68.7837	19
ПС 110 кВ ГВФ	2Т	25	8.845	1.271	8.936	35.74	8.46	1.224	8.548	34.19	8.05	1.069	8.12	32.48	8.089	1.094	8.163	32.65	8.845	1.271	8.936	35.7441	19
ПС 110 кВ ГВФ	3Т	25	1.177	0	1.177	4.709	1.217	0	1.217	4.867	1.289	0	1.289	5.155	1.296	0	1.296	5.184	1.296	0	1.296	5.184	19
ПС 35 кВ Георгиевка	1Т	4	1.44	0.2	1.454	36.35	1.08	0.16	1.092	27.29	1.68	0.24	1.697	42.43	0.4	0.08	0.408	10.2	1.68	0.24	1.697	42.4264	19
ПС 35 кВ Георгиевка	2Т	4	0.84	0.2	0.863	21.59	1.24	0.2	1.256	31.4	0.92	0.24	0.951	23.77	1.52	0.04	1.521	38.01	1.52	0.24	1.521	38.0132	19
ПС 35 кВ Горка	1Т	6.3	4.022	0.603	4.067	64.55	3.897	0.61	3.944	62.6	3.93	0.566	3.971	63.03	3.838	0.552	3.878	61.55	4.022	0.61	4.067	64.5544	19
ПС 35 кВ Горка	2Т	10	9.181	1.689	9.335	93.35	9.038	1.685	9.194	91.94	9.079	1.658	9.229	92.29	8.471	1.519	8.606	86.06	9.181	1.689	9.335	93.3543	19
ПС 110 кВ Городская	1Т	40	11.77	2.128	11.96	29.9	11.05	1.944	11.22	28.05	15	2.315	15.18	37.96	15.42	2.387	15.6	39	15.42	2.387	15.6	38.9972	19
ПС 110 кВ Городская	2Т	40	11.6	1.994	11.77	29.41	10.5	2.005	10.69	26.72	17.41	2.556	17.6	44	17.95	2.617	18.14	45.34	17.95	2.617	18.14	45.3396	19
ПС 110 кВ Горький	1Т	40	23.68	4.857	24.17	60.43	23.03	4.774	23.52	58.8	25.09	5.651	25.72	64.3	23.69	5.445	24.31	60.77	25.09	5.651	25.72	64.2955	19
ПС 110 кВ Горький	2Т	40	28.51	6.232	29.19	72.97	27.18	6.046	27.84	69.61	28.07	6.248	28.76	71.89	27.99	6.055	28.64	71.59	28.51	6.248	29.19	72.9685	19
ПС 110 кВ Гродеково	1Т	16	6.72	4.88	8.305	51.91	8.76	2.28	9.052	56.57	9.2	2.28	9.478	59.24	8.32	2	8.557	53.48	9.2	4.88	9.478	59.2395	19
ПС 110 кВ Гродеково	2Т	16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ ДВНТФ	1Т	6.3	0.08	0	0.08	1.27	0	0	0	0	0.08	0	0.08	1.27	0.32	0	0.32	5.079	0.32	0	0.32	5.07937	19
ПС 110 кВ Дормидонтовка	1Т	6.3	0.52	0	0.52	8.254	0.53	0	0.53	8.413	1.12	0	1.12	17.78	0.52	0	0.52	8.254	1.12	0	1.12	17.7778	19
ПС 35 кВ Дружба	1Т	2.5	0.64	0.12	0.651	26.05	0.76	0.08	0.764	30.57	1.08	0.12	1.087	43.47	0.84	0.08	0.844	33.75	1.08	0.12	1.087	43.4658	19
ПС 35 кВ Дружба	2Т	2.5	0.52	0.04	0.522	20.86	0.68	0.08	0.685	27.39	0.48	0.08	0.487	19.46	0.72	0.04	0.721	28.84	0.72	0.08	0.721	28.8444	19
ПС 35 кВ Дубки	1Т	6.3	3.337	0.508	3.376	53.58	3.043	0.462	3.078	48.86	3.558	0.499	3.593	57.03	3.492	0.521	3.531	56.04	3.558	0.521	3.593	57.0294	19
ПС 35 кВ Дубки	2Т	6.3	1.64	0.312	1.67	26.5	1.598	0.31	1.628	25.84	2.004	0.323	2.03	32.22	1.822	0.317	1.849	29.35	2.004	0.323	2.0		

ПС 110 кВ Корфовская	1Т	10	5.685	2.303	6.134	61.34	5.356	2.234	5.803	58.03	6.115	2.558	6.629	66.29	5.627	1.948	5.955	59.55	6.115	2.558	6.629	66.2891
ПС 110 кВ Корфовская	2Т	16	10.07	3.196	10.57	66.06	9.874	3.14	10.36	64.76	9.796	3.224	10.31	64.45	9.39	2.953	9.843	61.52	10.07	3.224	10.57	66.0579
ПС 110 кВ Котиково	1Т	6.3	0.562	0.07	0.566	8.99	0.696	0.07	0.7	11.1	0.682	0.07	0.686	10.88	0.626	0	0.626	9.937	0.696	0.07	0.7	11.1034
ПС 110 кВ Котиково	2Т	6.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ КПУ	1Т	16	2.1	0.9	2.285	14.28	2.1	0.6	2.184	13.65	3	0.6	3.059	19.12	3	0.9	3.132	19.58	3	0.9	3.132	19.5756
ПС 110 кВ КПУ	2Т	16	1.8	0.6	1.897	11.86	1.8	0.6	1.897	11.86	2.1	0.9	2.285	14.28	2.1	0.9	2.285	14.28	2.1	0.9	2.285	14.2796
ПС 110 кВ Красицкая	1Т	6.3	0.48	0.12	0.495	7.854	0.36	0	0.36	5.714	0.48	0	0.48	7.619	0.36	0.12	0.379	6.023	0.48	0.12	0.495	7.85353
ПС 110 кВ Красицкая	2Т	6.3	0.112	0	0.112	1.778	0.224	0	0.224	3.556	0.238	0	0.238	3.778	0.238	0	0.238	3.778	0.238	0	0.238	3.77778
ПС 35 кВ Краснознаменка	1Т	2.5	0.9	0.3	0.949	37.95	0.75	0.27	0.797	31.88	0.78	0.27	0.825	33.02	0.78	0.24	0.816	32.64	0.9	0.3	0.949	37.9473
ПС 35 кВ Краснознаменка	2Т	2.5	0.12	0.03	0.124	4.948	0.09	0.03	0.095	3.795	0.06	0.03	0.067	2.683	0.12	0	0.12	4.8	0.12	0.03	0.124	4.94773
ПС 35 кВ Краснореченская	1Т	6.3	4.896	1.872	5.242	83.2	4.464	0.288	4.473	7.1	2.664	0.36	2.688	42.67	3.6	0.576	3.646	57.87	4.896	1.872	5.242	83.2013
ПС 35 кВ Краснореченская	2Т	6.3	2.448	0.648	2.532	40.2	1.656	0.216	1.67	26.51	2.016	0.504	2.078	32.98	2.736	0.504	2.782	44.16	2.376	0.648	2.782	44.1593
ПС 110 кВ Лермонтовка	1Т	6.3	2.88	1.08	3.076	48.82	3	1.08	3.188	50.61	3.36	1.08	3.529	56.02	3	1.08	3.188	50.61	3.36	1.08	3.529	56.0207
ПС 110 кВ Лермонтовка	2Т	5.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 35 кВ М	1Т	10	5.328	1.258	5.474	54.74	4.877	1.037	4.986	49.86	5.021	1.315	5.19	51.9	5.174	1.229	5.318	53.18	5.328	1.315	5.474	54.745
ПС 35 кВ М	2Т	10	3.432	0.696	3.502	35.02	3.372	0.636	3.431	34.31	4.956	0.696	5.005	50.05	3.504	0.756	3.585	35.85	4.956	0.756	5.005	50.0463
ПС 110 кВ Малахит	1Т	6.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ Малахит	2Т	6.3	0.486	0.288	0.565	8.967	0.468	0.306	0.559	8.876	0.702	0.324	0.773	12.27	0.45	0.27	0.525	8.33	0.702	0.324	0.773	12.2724
ПС 110 кВ МЖК	1Т	16	3.991	0.703	4.053	25.33	3.751	0.684	3.813	23.83	5.616	0.766	5.668	35.42	5.52	0.73	5.568	34.8	5.616	0.766	5.668	35.4247
ПС 110 кВ МЖК	2Т	16	2.818	0.446	2.853	17.83	2.386	0.432	2.424	15.15	5.275	0.617	5.311	33.19	5.054	0.598	5.09	31.81	5.275	0.617	5.311	33.1946
ПС 110 кВ Мухен	1Т	7.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ Мухен	2Т	5.6	1.08	0.504	1.192	21.28	1.296	0.504	1.391	24.83	1.368	0.504	1.458	26.03	1.152	0.432	1.23	21.97	1.368	0.504	1.458	26.0337
ПС 35 кВ Маяк	1Т	6.3	3.28	2.88	4.365	69.28	1.95	3.36	3.885	61.66	0.64	0.32	0.716	11.36	2.87	0.56	2.924	46.41	3.28	3.36	4.365	69.2849
ПС 35 кВ Некрасовка	1Т	6.3	1.32	0.24	1.342	21.3	1.32	0.24	1.342	21.3	1.32	0.24	1.342	21.3	1.44	0.24	1.46	23.17	1.32	0.24	1.342	21.3274
ПС 35 кВ Некрасовка	2Т	4	1.2	0.24	1.224	30.59	1.2	0.24	1.224	30.59	1.68	0.36	1.718	42.95	1.92	0.36	1.953	48.84	1.92	0.36	1.953	48.8365
ПС 35 кВ НОВ	1Т	2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0.36	0.36	14.4	0	0.36	0.36	14.4
ПС 35 кВ НОВ	2Т	2.5	0.72	0.2	0.747	29.89	0.72	0.2	0.747	29.89	0.5	0.36	0.616	24.64	0.5	0.36	0.616	24.64	0.72	0.36	0.747	29.8905
ПС 110 кВ НПЗ	1Т	32	15.48	3.6	15.89	49.67	15.12	3.6	15.54	48.57	15.84	2.88	16.1	50.31	15.84	3.6	16.24	50.76	15.84	3.6	16.24	50.7623
ПС 110 кВ НПЗ	2Т	32	7.92	2.52	8.311	25.97	9.72	2.88	10.14	31.68	7.56	2.52	7.969	24.9	7.56	2.52	7.969	24.9	9.72	2.88	10.14	31.6803
ПС 110 кВ НПЗ-2	1Т	32	14.47	8.946	17.01	53.16	12.16	7.506	14.29	44.66	12.03	7.402	14.13	44.15	11.97	7.333	14.04	43.88	14.47	8.946	17.01	53.1575
ПС 110 кВ НПЗ-2	2Т	32	12.58	6.818	14.31	44.71	10.85	5.961	12.38	38.69	10.68	5.846	12.18	38.05	11.12	5.984	12.63	39.47	12.58	6.818	14.31	44.7095
ПС 35 кВ НС	1Т	6.3	0	0	0	0	0.774	0.456	0.899	14.26	0.793	0.462	0.918	14.57	0.76	0.441	0.879	13.95	0.793	0.462	0.918	14.5699
ПС 35 кВ НС-1	1Т	1.8	0.07	0.14	0.157	8.696	0.07	0.07	0.099	5.5	0.07	0.14	0.157	8.696	0.07	0.14	0.157	8.696	0.07	0.14	0.157	8.69582
ПС 35 кВ НС-2	1Т	1.6	0.21	0	0.21	13.13	0.21	0.105	0.235	14.67	0.21	0.105	0.235	14.67	0.105	0	0.105	6.563	0.21	0.105	0.235	14.6742
ПС 110 кВ Обор	1Т	2.5	0.36	0.12	0.379	15.18	0.36	0.12	0.379	15.18	0.36	0.12	0.379	15.18	0.36	0	0.36	14.4	0.36	0.12	0.379	15.1789
ПС 35 кВ ОПХ	1Т	4	3.56	0.72	3.632	90.8	2.48	0.52	2.534	63.35	3	0.6	3.059	76.49	3.24	0.6	3.295	82.38	3.56	0.72	3.632	90.802
ПС 35 кВ ОПХ	2Т	4	2.96	0.32	2.977	74.43	2.48	0.32	2.501	62.51	2.48	0.32	2.501	62.51	2.64	0.4	2.67	66.75	2.96	0.32	2.977	74.4312
ПС 110 кВ Осиновая речка	1Т	10	2.83	0.14	2.833	28.33	2.59	0.07	2.591	25.91	2.59	0.14	2.594	25.94	1.39	0.14	1.397	13.97	2.83	0.14	2.833	28.3346
ПС 110 кВ Осиновая речка	2Т	10	3.69	0	3.69	36.9	4.53	0.105	4.531	45.31	2.01	0.105	2.013	20.13	2.865	0	2.865	28.65	4.53	0.105	4.531	45.3122
ПС 35 кВ Очистные сооружения	1Т	4	0.24	0.12	0.268	6.708	0.3	0.12	0.323	8.078	0.54	0.24	0.591	14.77	0.48	0.12	0.495	12.37	0.54	0.24	0.591	14.7733
ПС 35 кВ Очистные	2Т	4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 35 кВ Парк Гайдара	1Т	16	1.566	0.295	1.594	9.96	2.65	0.367	2.675	16.72	2.857	0.394	2.884	18.02	1.814	0.313	1.841	11.51	2.857	0.394	2.884	18.0229
ПС 35 кВ Парк Гайдара	2Т	16	5.18	0.913	5.26	32.88	4.657	0.902	4.743	29.64	7.025	1.073	7.107	44.42	7.902	1.179	7.989	49.93	7.902	1.179	7.989	49.9342
ПС 35 кВ Переяславка	1Т	10	3.6	1.56	3.923	39.23	4.68	1.68	4.972	49.72	5.64	1.44	5.44	58.21	3.84	1.2	4.023	40.23	5.64	1.68	4.972	58.2093
ПС 110 кВ Петровици	1Т	6.3	2.38	0.28	2.396	38.04	2.38	0.42	2.417	38.36	2.24	0.56	2.309	36.65	2.66	0.42	2.693	42.75	2.66	0.56	2.693	42.7453
ПС 110 кВ Петровици	2Т	6.3	2.08	0.4	2.118	33.62	2.08	0.48	2.135	33.88	2.48	0.48	2.526	40.1	2.32	0.48	2.369	37.61	2.48	0.48	2.526	40.0956
ПС 110 кВ Племенрепродуктор	1Т	16	4.58	0.83	4.655	29.09	4.59	0.83	4.664	29.15	4.17	0.62	4.216	26.35	4.16	0.63	4.207	26.3	4.59	0.83	4.664	29.1527
ПС 110 кВ Племенрепродуктор	2Т	16	7.5	2.25	7.83	48.94	8.31	1.95	8.536	53.35	6.78	2.04	7.08	44.25	6.87	1.74	7.087	44.29	8.31	2.25	7.836	53.3483
ПС 35 кВ Протока	1Т	16	1.68	0.24	1.697	10.61	1.2	0.24	1.224	7.649	1.68	0.24	1.697	10.61	2.16	0.24	2.173	13.58	2.16	0.24	1.697	13.5831
ПС 35 кВ Протока	2Т	16	1.44	0.24	1.46	9.124	0.96	0.24	0.99	6.185	1.92	0.24	1.935	12.09	1.68	0.24	1.697	10.61	1.92	0.24	1.463	12.0934
ПС 35 кВ Прибрежная	1Т	4	0.266	0.166	0.314	7.839	0.266	0.167	0.314	7.852	0.266	0.161	0.311	7.773	0.264	0.162	0.31	7.744	0.266	0.167	0.314	7.85195
ПС 35 кВ Р	1Т	4	0.2	0	0.2	5	0.12	0	0.12	3	0.16	0	0.16	4	0.16	0	0.16	4	0.2	0	0.2	5
ПС 35 кВ Р	2Т	4	0.96	0.12	0.967	24.19	0.84	0.12	0.849	21.21	0.888	0.12	0.888	22.2	0.88	0.12	0.888	22.2	0.96	0.12	0.967	24.1868
ПС 35 кВ Ракинское	1Т	6.3	2	0.4	2.04	32.37	5.76	0.64	5.795	91.99	3.68	0.24	3.688	58.54	3.92	0.72	3.986	63.26	5.76	0.72	5.795	91.9912
ПС 35 кВ Ракинское	2Т	6.3	1.76	0.24	1.776	28.2	1.04	0.48	1.145	18.18	1.52	0.16	1.528	24.26	1.92	0.4	1.961	31.13	1.92	0.48	1.961	31.1305
ПС 35 кВ СВ	1Т	10	6.24	0.96	6.313	63.13	6	0.24	6.005	60.85	8.16	1.08	8.231	82.31	8.16	1.08	8.231	82.31	8.16	1.08	8.231	82.3116
ПС 35 кВ СВ	2Т	16	5.4	1.8	5.692	35.58	5.76	0.72	5.805	36.28	7.92	1.44	8.05	50.31	7.92							

ПС 35 кВ Фёдоровка	1Т	4	3.173	0.173	3.178	79.45	3.143	0.172	3.147	78.69	3.05	0.164	3.054	76.35	2.945	0.154	2.949	73.72	3.173	0.173	3.178	79.4533	
ПС 35 кВ Фёдоровка	2Т	4	3.806	0.61	3.854	96.36	3.799	0.608	3.847	96.18	3.619	0.575	3.665	91.61	3.49	0.541	3.532	88.3	3.806	0.61	3.854	96.3602	
ПС 110 кВ Хабаровск-2-тяга	1Т	40	9.007	11.44	14.56	36.39	8.202	10.23	13.11	32.78	7.845	11.05	13.55	33.89	9.451	12.67	15.8	39.51	9.451	12.67	15.8	39.5121	
ПС 110 кВ Хабаровск-2-тяга	2Т	40	9.002	11.29	14.44	36.1	8.056	9.896	12.76	31.9	7.3	10.12	12.47	31.19	9.381	12.2	15.39	38.48	9.381	12.2	15.39	38.4763	
ПС 35 кВ Хабаровск-2 35кВ	1Т	6.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ПС 35 кВ Хабаровск-2 35кВ	2Т	6.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ПС 35 кВ Ханкайская	1Т	6.3	0.452	0	0.452	7.17	0.453	0	0.453	7.185	0.501	0	0.501	7.947	0.489	0	0.489	7.764	0.501	0	0.501	7.94667	
ПС 35 кВ Ханкайская	2Т	6.3	0.333	0.189	0.383	6.077	0.335	0.191	0.385	6.115	0.341	0.188	0.389	6.179	0.336	0.188	0.386	6.119	0.341	0.191	0.389	6.17925	
ПС 110 кВ Хор	1Т	16	1.6	0.5	1.676	10.48	1.6	0.5	1.676	10.48	2.38	0.68	2.475	15.47	2.74	0.86	2.872	17.95	2.74	0.86	2.872	17.9487	
ПС 110 кВ Хор	2Т	16	1.98	0.54	2.052	12.83	1.98	0.54	2.052	12.83	3.24	0.9	3.363	21.02	3.78	0.9	3.886	24.29	3.78	0.9	3.886	24.2854	
ПС 110 кВ ХЭС	1Т	40	19.83	5.362	20.54	51.34	17.82	5.006	18.51	46.28	26.75	6.135	27.45	68.62	27.47	6.312	28.18	70.46	27.47	6.312	28.18	70.4602	
ПС 110 кВ ХЭС	2Т	40	22.74	5.702	23.45	58.61	21.12	5.498	21.83	54.57	31.2	7.077	31.99	79.97	31.63	7.158	32.43	81.07	31.63	7.158	32.43	81.0681	
ПС 110 кВ Ц	1Т	40	6.24	1.44	6.404	16.01	5.28	0.96	5.367	13.42	7.2	1.44	7.343	18.36	7.68	1.44	7.814	19.53	7.68	1.44	7.814	19.5346	
ПС 110 кВ Ц	2Т	40	6.72	0.96	6.788	16.97	6.24	0.96	6.313	15.78	8.16	1.44	8.286	20.72	9.6	0.96	9.648	24.12	9.6	1.44	9.648	24.1197	
ПС 35 кВ Чернореченская	1Т	6.3	3	1.08	3.188	50.61	3.12	0.96	3.264	51.82	3.12	1.08	3.302	52.41	3	1.08	3.188	50.61	3.12	1.08	3.302	52.4069	
ПС 35 кВ Чернореченская	2Т	6.3	1.44	0.36	1.484	23.56	1.44	0.24	1.46	23.17	1.44	0.24	1.46	23.17	1.44	0.24	1.46	23.17	1.44	0.36	1.484	23.5606	
ПС 35 кВ Черняево	1Т	4	0.75	0.18	0.771	19.28	0.87	0.21	0.895	22.37	0.87	0.15	0.883	22.07	0.66	0.12	0.671	16.77	0.87	0.21	0.895	22.3747	
ПС 35 кВ Шереметьево	1Т	2.5	0.24	0.08	0.253	10.12	0.24	0.08	0.253	10.12	0.2	0.04	0.204	8.158	0.12	0.08	0.144	5.769	0.24	0.08	0.253	10.1193	
ПС 35 кВ Шереметьево	2Т	2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0.04	0.04	0.057	2.263	0.04	0.04	0.057	2.26274
ПС 35 кВ Эмалзавод	1Т	16	4.318	0.554	4.353	27.21	4.013	0.538	4.049	25.3	4.805	0.55	4.836	30.23	4.812	0.559	4.844	30.28	4.812	0.559	4.844	30.2774	
ПС 35 кВ Эмалзавод	2Т	16	5.302	0.912	5.379	33.62	4.908	0.91	4.992	31.2	6.569	0.996	6.644	41.52	6.442	1.003	6.519	40.75	6.569	1.003	6.644	41.5243	
ПС 110 кВ Энергомаш	1Т	25	4.082	0.67	4.137	16.55	3.977	0.653	4.03	16.12	6.835	0.828	6.885	27.54	7.224	0.994	7.292	29.17	7.224	0.994	7.292	29.168	
ПС 110 кВ Энергомаш	2Т	25	2.791	0.418	2.822	11.29	2.525	0.398	2.556	10.22	4.411	0.679	4.463	17.85	4.529	0.65	4.575	18.3	4.529	0.679	4.575	18.3011	
ПС 110 кВ Южная	1Т	25	9.627	3.307	10.18	40.72	9.404	3.243	9.947	39.79	12.12	4.238	12.84	51.34	11.5	3.936	12.15	48.62	12.12	4.238	12.84	51.343	
ПС 110 кВ Южная	2Т	25	17.14	4.074	17.62	70.46	16.36	3.806	16.79	67.17	19.17	5.49	19.94	79.75	18.7	5.489	19.49	77.96	19.17	5.49	19.94	79.7477	
ПС 110 кВ ЮМР	1Т	25	11.22	3.074	11.64	46.55	10.82	3.019	11.24	44.94	15.55	3.701	15.98	63.93	16.08	3.325	16.42	65.69	16.08	3.701	16.42	65.6949	
ПС 110 кВ ЮМР	2Т	25	13.17	3.589	13.65	54.59	12.6	3.451	13.07	52.27	14.66	3.745	15.13	60.51	15.09	3.586	15.51	62.04	15.09	3.745	15.51	62.0359	
ПС 110 кВ Азимут	1Т	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ПС 110 кВ Азимут	2Т	6.3	0.96	0.24	0.99	15.71	0.84	0.24	0.874	13.87	1.44	0.6	1.56	24.76	1.2	0.36	1.253	19.89	1.44	0.6	1.56	24.7619	
ПС 35 кВ Б	1Т	16	1.26	0.36	1.31	8.19	1.26	0.36	1.31	8.19	1.8	0.36	1.836	11.47	1.8	0.36	1.836	11.47	1.8	0.36	1.836	11.4728	
ПС 35 кВ Б	2Т	10	1.56	0.36	1.601	16.01	1.44	0.36	1.484	14.84	2.04	0.36	2.072	20.72	2.4	0.48	2.448	24.48	2.4	0.48	2.448	24.4753	
ПС 110 кВ Байкальская	1Т	10	3.6	1.5	3.9	39	3.5	1.5	3.808	38.08	4.2	1.7	4.531	45.31	4.6	1.7	4.904	49.04	4.6	1.7	4.904	49.0408	
ПС 110 кВ Байкальская	2Т	25	2.246	0.636	2.334	9.336	2.25	0.638	2.339	9.354	3.113	0.831	3.223	12.89	2.885	0.686	2.965	11.86	3.113	0.831	3.223	12.8901	
ПС 110 кВ БАМ ПТФ	1Т	10	1.901	0.634	2.004	20.04	1.765	0.588	1.86	18.6	1.966	0.655	2.073	20.73	1.894	0.631	1.996	19.96	1.966	0.655	2.073	20.7258	
ПС 110 кВ Береговая	1Т	25	4.442	0.933	4.539	18.16	4.068	0.852	4.156	16.62	8.089	1.395	8.208	32.83	8.603	1.548	8.741	34.97	8.603	1.548	8.741	34.9651	
ПС 110 кВ Береговая	2Т	25	4.837	0.891	4.919	19.67	4.508	0.881	4.593	18.37	8.051	1.638	8.216	32.86	9.08	1.849	9.267	37.07	9.08	1.849	9.267	37.0664	
ПС 35 кВ Болин	1Т	4	1.14	0.18	1.154	28.85	1.26	0.24	1.283	32.07	1.26	0.24	1.283	32.07	1.2	0.18	1.213	30.34	1.26	0.24	1.283	32.0663	
ПС 35 кВ Болин	2Т	1.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ПС 35 кВ Брикан	1Т	4	0.336	0.12	0.357	8.92	0.36	0.12	0.379	9.487	0.408	0.12	0.425	10.63	0.36	0.096	0.373	9.315	0.408	0.12	0.425	10.632	
ПС 110 кВ Водозабор	1Т	16	1.198	0.413	1.268	7.923	1.198	0.413	1.268	7.923	1.169	0.403	1.236	7.726	1.168	0.402	1.235	7.719	1.198	0.413	1.268	7.92251	
ПС 110 кВ Водозабор	2Т	16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ПС 110 кВ Вознесенская	1Т	6.3	1.64	0.2	1.652	26.22	1.28	0.16	1.29	20.48	1.84	0.363	1.875	29.77	1.56	0.2	1.573	24.96	1.84	0.363	1.875	29.7684	
ПС 110 кВ Вознесенская	2Т	2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ПС 110 кВ Гайгер	1Т	40	0.22	0.076	0.232	0.581	0.217	0.075	0.229	0.572	0.228	0.078	0.241	0.602	0.22	0.076	0.232	0.581	0.228	0.078	0.241	0.60214	
ПС 110 кВ Гайгер	2Т	40	0.84	0.06	0.842	2.105	0.9	0.12	0.908	2.27	0.9	0.06	0.902	2.255	0.72	0	0.72	1.8	0.9	0.12	0.908	2.26991	
ПС 110 кВ Горная	1Т	10	3.6	2.7	4.5	45	3.24	2.52	4.105	41.05	3.42	2.34	4.144	41.44	3.78	2.7	4.645	46.45	3.78	2.7	4.645	46.4526	
ПС 110 кВ Горная	2Т	6.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ПС 35 кВ Городская (г.Комсомольск-на-Амуре)	1Т	16	3.069	1.364	3.359	20.99	2.798	1.244	3.062	19.14	5.909	2.626	6.466	40.42	6.304	2.802	6.899	43.12	6.304	2.802	6.899	43.1168	
ПС 35 кВ Городская (г.Комсомольск-на-Амуре)	2Т	16	4.029	1.791	4.409	27.56	3.696	1.643	4.045	25.28	6.482	2.881	7.094	44.34	7.449	3.311	8.152	50.95	7.449	3.311	8.152	50.9479	
ПС 35 кВ Дальняя	1Т	2.5																					
ПС 35 кВ Дуки	1Т	1.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
ПС 35 кВ Дуки	2Т	2.5	0.42	0.24	0.484	19.35	0.48	0.06	0.484	19.35	0.42	0.06	0.424	16.97	0.48	0.06	0.484	19.35	0.48	0.24	0.484	19.3494	
ПС 35 кВ Западная	1Т	10	0.9	0.36	0.969	6.993	1.08	0.18	1.095	10.95	1.62	0.54	1.708	17.08	1.26	0.36	1.31	13.1	1.62	0.54	1.708	17.0763	
ПС 35 кВ Западная	2Т	16	1.92	0.24	1.935	12.09	2.16	0.48	2.213	13.83	3.12	0.72	3.202	20.01	2.64	0.72	2.736	17.1	3.12	0.72	3.202	20.0125	
ПС 35 кВ Индустриальная	1Т	4	0.36	0.12	0.379	9.487	0.36	0.12	0.379	9.487	0.42	0.24	0.484	12.09	0.42	0.18	0.457	11.42	0.42	0.24	0.484	12.0934	
ПС 35 кВ Индустриальная	2Т	4	0.16	0.08	0.179	4.472	0.16	0.12	0.2	5	0.2	0.08	0.215	5.385	0.2	0.08	0.215	5.385	0.2	0.12	0.215	5.38516	
ПС 110 кВ Иннокентьевка	1Т	6.3	0.64	0.08	0.645	10.24	0.56	0.08	0.566	8.979	0.72	0.08	0.724	11.5	0.64	0.16	0.66	10.47	0.72	0.16	0.724	11.4989	
ПС 110 кВ Иннокентьевка	2Т	6.3	0	0	0																		

ПС 35 кВ ННЗ	2Т	10	2.4	0.24	2.412	24.12	2.44	0.28	2.456	24.56	2.4	0.24	2.412	24.12	1.08	0.24	1.106	11.06	2.44	0.28	2.456	24.5601
ПС 35 кВ Объект-10	1Т	2.5	0.432	0.12	0.448	17.93	0.408	0.12	0.425	17.01	0.432	0.12	0.448	17.93	0.48	0.12	0.495	19.79	0.48	0.12	0.495	19.7909
ПС 35 кВ Объект-202	1Т	2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 35 кВ Объект-202	2Т	2.5	0.336	0.144	0.366	14.62	0.384	0.144	0.41	16.4	0.384	0.096	0.396	15.83	0.336	0.144	0.366	14.62	0.384	0.144	0.41	16.4045
ПС 110 кВ Озерная	1Т	6.3	0.6	0	0.6	9.524	0.84	0.12	0.849	13.47	0.72	0.12	0.73	11.59	0.84	0	0.84	13.33	0.84	0.12	0.849	13.4687
ПС 110 кВ Озерная	2Т	6.3	1.2	0.12	1.206	19.14	0.84	0.12	0.849	13.47	1.2	0.12	1.206	19.14	1.32	0	1.32	20.95	1.32	0.12	1.32	20.9524
ПС 110 кВ Падали	1Т	2.5	0.864	0.216	0.891	35.62	0.648	0.288	0.709	28.36	0.648	0.288	0.709	28.36	0.72	0.288	0.775	31.02	0.864	0.288	0.891	35.6236
ПС 110 кВ Перевальная	1Т	6.3																				
ПС 110 кВ Пивань	1Т	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ Пивань	2Т	10	2.267	0.806	2.406	24.06	2.327	0.827	2.47	24.7	2.081	0.74	2.208	22.08	1.941	0.69	2.06	20.6	2.327	0.827	2.47	24.6971
ПС 110 кВ Привокзальная	1Т	16	6.751	2.25	7.116	44.47	6.225	2.075	6.562	41.01	7.895	2.632	8.322	52.01	8.737	2.912	9.209	57.56	8.737	2.912	9.209	57.5569
ПС 110 кВ Привокзальная	2Т	16	4.064	1.355	4.284	26.78	3.677	1.226	3.876	24.23	5.793	1.931	6.107	38.17	6.282	2.094	6.622	41.39	6.282	2.094	6.622	41.3884
ПС 35 кВ Приусадбная	1Т	10	1.26	0.36	1.31	13.1	1.62	0.54	1.708	17.08	1.62	0.54	1.708	17.08	1.26	0.36	1.371	13.71	1.62	0.54	1.708	17.0763
ПС 35 кВ Приусадбная	2Т	1.8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 35 кВ ПТО	1Т	10	0.504	0.072	0.509	5.091	0.432	0.072	0.438	4.38	0.792	0.144	0.805	8.05	0.648	0.144	0.664	6.638	0.792	0.144	0.805	8.04984
ПС 110 кВ Ручей	1Т	6.3	0.27	0.018	0.271	4.295	0.324	0.036	0.326	5.175	0.27	0.036	0.272	4.324	0.306	0.018	0.307	4.866	0.324	0.036	0.326	5.17451
ПС 110 кВ Ручей	2Т	2.5	0.36	0.144	0.388	15.51	0.36	0.162	0.395	15.79	0.27	0.108	0.291	11.63	0.396	0.144	0.421	16.85	0.396	0.162	0.421	16.8548
ПС 35 кВ Совхоз Комсомольский	1Т	2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 35 кВ Совхоз Комсомольский	2Т	4	0.44	0.04	0.442	11.05	0.48	0.04	0.482	12.04	0.4	0.04	0.402	10.05	0.36	0.04	0.362	9.055	0.48	0.04	0.482	12.0416
ПС 110 кВ Северная	1Т	10	0.167	0.058	0.177	1.768	0.172	0.059	0.182	1.818	0.218	0.075	0.231	2.31	0.193	0.067	0.204	2.042	0.218	0.075	0.231	2.31042
ПС 110 кВ Северная	2Т	10	0.188	0.065	0.199	1.989	0.181	0.062	0.192	1.919	0.285	0.098	0.301	3.014	0.202	0.07	0.214	2.14	0.285	0.098	0.301	3.0136
ПС 35 кВ Снежная	1Т	4	0.72	0.12	0.73	18.25	0.6	0.24	0.646	16.16	0.84	0.48	0.967	24.19	0.84	0.24	0.874	21.84	0.84	0.48	0.967	24.1868
ПС 35 кВ Снежная	2Т	4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ Солнечная	1Т	6.3	1.08	0.24	1.106	17.56	1.08	0.36	1.138	18.07	1.2	0.24	1.224	19.42	1.44	0.36	1.484	23.56	1.44	0.36	1.484	23.5606
ПС 110 кВ Солнечная	2Т	6.3	1.44	0.36	1.484	23.56	1.32	0.36	1.368	21.72	1.56	0.24	1.578	25.05	2.4	0.48	2.448	38.85	2.4	0.48	2.448	38.8497
ПС 35 кВ Таежная	1Т	4	0.112	0.064	0.129	3.225	0.112	0.064	0.129	3.225	0.128	0.064	0.143	3.578	0.112	0.048	0.122	3.046	0.112	0.048	0.122	3.046143
ПС 35 кВ Таежная	2Т	2.5	0.016	0.016	0.023	0.905	0.016	0.016	0.023	0.905	0	0.016	0.016	0.64	0.032	0.016	0.036	1.431	0.032	0.016	0.036	1.43108
ПС 35 кВ ТН	1Т	10	2.8	0.6	2.864	28.64	2.8	0.6	2.864	28.64	3.6	0.64	3.656	36.56	3.57	0.57	3.615	36.15	3.6	0.64	3.656	36.5645
ПС 35 кВ ТН	2Т	7.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ Троицкая	1Т	6.3	2.4	0	2.4	38.1	3.6	0	3.6	57.14	3.6	1.2	3.795	60.23	2.4	1.2	2.683	42.59	3.6	1.2	3.795	60.2339
ПС 110 кВ Троицкая	2Т	6.3	3	0.6	3.059	48.56	3.6	1.2	3.795	60.23	3	1.2	3.231	51.29	3	0.6	3.059	48.56	3.6	1.2	3.795	60.2339
ПС 35 кВ Тейсин	1Т	4	2.016	0.144	2.021	50.53	1.824	0.384	1.864	46.6	1.824	0.384	1.864	46.6	2.304	0.48	2.353	58.84	2.304	0.48	2.353	58.8367
ПС 110 кВ Хурба	1Т	10	3.185	0.504	3.225	32.25	3.126	0.676	3.198	31.98	3.193	0.721	3.274	32.74	3.106	0.704	3.185	31.85	3.193	0.721	3.274	32.7354
ПС 110 кВ Хурба	2Т	16	3.653	1.143	3.828	23.92	3.562	1.478	3.857	24.11	4.055	1.743	4.414	27.58	3.92	1.675	4.263	26.64	4.055	1.743	4.414	27.5848
ПС 110 кВ ЦОФ	1Т	15	4.68	1.44	4.897	32.64	5.22	1.8	5.522	36.81	7.38	2.52	7.798	51.99	5.22	1.62	5.466	36.44	7.38	2.52	7.798	51.9892
ПС 110 кВ ЦОФ	2Т	15	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ Эльбан	1Т	16	4.082	1.174	4.248	26.55	3.841	1.174	4.016	25.1	4.712	1.374	4.908	30.68	4.947	1.372	5.134	32.09	4.947	1.374	5.134	32.086
ПС 110 кВ Эльбан	2Т	16	6.344	2.553	6.838	42.74	5.785	2.518	6.309	39.43	6.486	2.643	7.003	43.77	7.632	3.179	8.267	51.67	7.632	3.179	8.267	51.6717
ПС 35 кВ ЭТЗ	1Т	16	1.98	0.54	2.052	12.83	1.62	0.72	1.773	11.08	3.96	0.9	4.061	25.38	3.96	0.9	4.061	25.38	3.96	0.9	4.061	25.3812
ПС 35 кВ ЭТЗ	2Т	10	1.44	0.36	1.484	14.84	1.8	0.36	1.836	18.36	2.34	0.54	2.401	24.01	1.98	0.54	2.052	20.52	3.94	0.54	2.401	24.015
ПС 110 кВ Белая Гора	1Т	6.3	3.528	0.36	3.546	56.29	3.528	0.36	3.546	56.29	3.996	0.6	4.041	64.14	3.432	0.48	3.465	55.01	3.996	0.6	4.041	64.1396
ПС 110 кВ Белая Гора	2Т	6.3	3.684	0.84	3.779	59.98	3.768	0.84	3.86	61.28	4.188	0.96	4.297	68.2	3.804	0.84	3.896	61.84	4.188	0.96	4.297	68.2003
ПС 110 кВ Маго	1Т	16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 110 кВ Многовершинная	1Т	10	7.92	1.98	8.164	81.64	7.56	1.98	7.815	78.15	7.02	2.16	7.345	73.45	6.48	1.8	6.725	67.25	7.92	2.16	8.164	81.6375
ПС 110 кВ Многовершинная	2Т	10	8.82	2.7	9.224	92.24	9.72	2.16	9.957	99.57	8.1	2.52	8.483	84.83	8.1	2.52	8.483	84.83	9.72	2.7	9.957	99.5711
ПС 110 кВ Окоча	1Т	25	6.8	2.7	7.316	29.27	6.7	2.8	7.262	29.05	8.1	3.2	8.709	34.84	8.1	3	8.638	34.55	8.1	3.2	8.709	34.8368
ПС 110 кВ Окоча	2Т	25	7.2	3	7.8	31.2	7.2	3.2	7.879	31.52	8.8	3.6	9.508	38.03	8.5	3.3	9.118	36.47	8.8	3.6	9.508	38.0316
ПС 110 кВ Эгте	1Т	25	6.6	1.8	6.841	27.36	6.6	1.9	6.868	27.47	7.8	2.3	8.132	32.53	7.7	2	7.956	31.82	7.8	2.3	8.132	32.5281
ПС 110 кВ Эгте	2Т	25	6.3	0.9	6.364	25.46	6.3	1	6.379	25.52	7.4	1.4	7.531	30.13	7.5	1.2	7.595	30.38	7.5	1.4	7.595	30.3816
ПС 35 кВ Городская (г.Советская Гавань)	1Т	6.3	3.36	0.6	3.413	54.18	3.36	0.6	3.413	54.18	4.17	0.6	4.213	66.87	3.825	0.6	3.872	61.46	4.17	0.6	4.213	66.8721
ПС 35 кВ Кислородная	1Т	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 35 кВ Кислородная	2Т	16	3.3	0.9	3.421	21.38	2.7	0.6	2.766	17.29	5.1	1.5	5.316	33.23	2.7	0.6	2.766	17.29	5.1	1.5	5.316	33.2251
ПС 35 кВ Лесозаводская	1Т	2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 35 кВ Лесозаводская	2Т	6.3	0.2	0.04	0.204	3.237	0.2	0.04	0.204	3.237	0.15	0.03	0.153	2.428	0.21	0.06	0.218	3.467	0.21	0.06	0.218	3.46672
ПС 35 кВ Монгохто	1Т	4	3.24	0.6	3.295	82.38	3.18	0.6	3.236	80.9	3.42	0.6	3.472	86.81	3.42	0.6	3.472	86.81	3.42	0.6	3.472	86.8058
ПС 35 кВ Монгохто	2Т	4	0.32	0	0.32	8	0.32	0	0.32	8	0.4	0	0.4	10	0.32	0	0.32	8	0.4	0	0.4	10
ПС 35 кВ РП-1	1Т	3.2	0.42	0.12	0.437	13.65	0.3	0.12	0.323	10.1	0.48	0.12	0.495	15.46	0.54	0.3	0.618	19.3	0.54	0.3	0.618	19.3043
ПС 35 кВ РП-1	2Т	4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
ПС 35 кВ РП-4	1Т	6.3	1.9	0.4	1.942	30.82	1.7	0.3	1.726	27.4	2.3	0.4	2.335	37.06	2.5	0.4	2.532					

